




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1008-Mason Sand
Specification Mason Sand
Period 07/19/2024 - 07/26/2024

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	7	100	0.0	97-100	
#8 (2.36mm)	7	100	0.0	97-100	
#16 (1.18mm)	7	100	0.0	90-100	
#30 (.6mm)	7	99	1.3	65-100	
#50 (.3mm)	7	88	3.1	35-90	
#100 (.15mm)	7	21	6.3	0-40	
#200 (75µm)	7	0.3	0.10		
Pan	7	0.0	0.00		
FM	7	0.93	0.095		
Total Moisture	7	3.7	0.44	0-6\3	0-7
D10 (ES)	7	0.11	0.011		
D50	7	0.20	0.010		
D60	7	0.22	0.013		
Cc	7	1.12	0.056		
Cu	7	2.12	0.104		



Query

Query Selections

Date Created 07/26/2024

Date Range 07/19/2024 - 07/26/2024

Plant Haines City Mine (FDOT Pit #16-024)

Sample Type Shipping