



12/01/2024

To Whom it may concern:

This material is currently produced at our "Green Bay" facility (FDOT mine #16-608) and certified utilizing the "QC Certification System" as outlined in chapter 14 of the Aggregate Rule (14-103 F.A.C.). This material meets all current requirements of section 902 (Fine Aggregate 902-1 through 902-2.2) of the F.D.O.T Standard Specification for Road and Bridge Construction. Each load is certified by an individual ticket.

### 1001-FDOT Concrete Silica Sand Code F01

| Procedure | Sieve/Test   | Average | Unit | FLDOT Silica Sand |
|-----------|--------------|---------|------|-------------------|
|           | #4 (4.75mm)  | 100     | %    | 95-100            |
|           | #8 (2.36mm)  | 100     | %    | 85-100            |
|           | #16 (1.18mm) | 95      | %    | 65-97             |
|           | #30 (.6mm)   | 60      | %    | 25-70             |
|           | #50 (.3mm)   | 22      | %    | 5-35              |
|           | #100 (.15mm) | 1       | %    | 0-7               |
|           | #200 (75µm)  | 0       | %    | 0-4               |

Sincerely,

## Mario Cardenas

Quality Control Manager  
E.R. Jahna Ind, Inc.  
Office: 352-394-7455  
Cell: 863-557-0342  
Fax: 352-394-8730

**Name/Title** Mario Cardenas / Quality Control Manager