




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1008-Mason Sand
Specification Mason Sand
Period 12/09/2024 - 12/16/2024

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	7	100	0.0	97-100	
#8 (2.36mm)	7	100	0.0	97-100	
#16 (1.18mm)	7	100	0.0	90-100	
#30 (.6mm)	7	95	1.3	65-100	
#50 (.3mm)	7	70	3.2	35-90	
#100 (.15mm)	7	15	4.3	0-40	
#200 (75µm)	7	0.1	0.04		
Pan	7	0.0	0.00		
FM	7	1.20	0.039		
Total Moisture	7	3.8	0.81	0-6\3	0-7
D10 (ES)	7	0.12	0.018		
D50	7	0.23	0.008		
D60	7	0.27	0.008		
Cc	7	1.01	0.082		
Cu	7	2.17	0.317		



Query

Query Selections
Date Created 12/16/2024
Date Range 12/09/2024 - 12/16/2024
Plant Haines City Mine (FDOT Pit #16-024)
Sample Type Shipping