




Basic Quality Statistical Summary Report

Plant 1030-Haines City Mine (FDOT Pit #16-024)
Product 1001-FDOT Concrete Silica Sand Code F01
Specification FDOT Concrete Silica Sand Code F01
Period 02/14/2025 - 02/21/2025

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	9	100	0.0		95-100
#8 (2.36mm)	9	100	0.0		85-100
#16 (1.18mm)	9	95	0.5		65-97
#30 (.6mm)	9	61	3.9	27-68	25-70
#50 (.3mm)	9	23	2.9	7-34	5-35
#100 (.15mm)	9	3	0.8	0-6	0-7
#200 (75µm)	9	0	0.0		0-4
Pan	9	0	0.0		
FM	9	2.18	0.067	2.05-2.37/2.2	2-2.4
Grad Loss	9	0.014	0.0287		
Total Moisture	7	2.1	0.89		
D10 (ES)	9	0.19	0.010		
D50	9	0.49	0.028		
D60	9	0.59	0.038		
Cc	9	1.02	0.038		
Cu	9	3.04	0.185		



Query

Query Selections
Date Created 02/21/2025
Date Range 02/14/2025 - 02/21/2025
Plant Haines City Mine (FDOT Pit #16-024)
Sample Type Shipping