




# Basic Quality Statistical Summary Report

**Plant** 1030-Haines City Mine (FDOT Pit #16-024)  
**Product** 1008-Mason Sand  
**Specification** Mason Sand  
**Period** 02/14/2025 - 02/21/2025

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	9	100	0.0	97-100	
#8 (2.36mm)	9	100	0.0	97-100	
#16 (1.18mm)	9	100	0.0	90-100	
#30 (.6mm)	9	99	1.2	65-100	
#50 (.3mm)	9	90	6.9	35-90	
#100 (.15mm)	9	20	5.1	0-40	
#200 (75µm)	9	0.3	0.13		
Pan	9	0.0	0.00		
FM	9	0.92	0.123		
Total Moisture	8	4.6	1.96	0-6\3	0-7
D10 (ES)	9	0.11	0.010		
D50	9	0.20	0.012		
D60	9	0.22	0.012		
Cc	9	1.14	0.057		
Cu	9	2.07	0.099		



**Query**

Query Selections  
Date Created 02/21/2025  
Date Range 02/14/2025 - 02/21/2025  
Plant Haines City Mine (FDOT Pit #16-024)  
Sample Type Shipping