




Basic Quality Statistical Summary Report

Plant 2010-Ortona Sand Company (FDOT Pit # 05-045)
Product 1004-Well Point Sand
Specification Well Point Sand
Period 02/14/2025 - 02/21/2025

Sieve/Test	Tests	Average	St Dev	Target	Specification
#4 (4.75mm)	6	100	0.0	100-100	
#8 (2.36mm)	6	100	0.0	85-100	
#16 (1.18mm)	6	94	0.5	50-95	
#30 (.6mm)	6	37	2.1	0-55	
#50 (.3mm)	6	5	2.7	0-35	
#100 (.15mm)	6	0	0.5	0-5	
#200 (75µm)	6	0.0	0.00		
Pan	6	0.0	0.00		
FM	6	2.64	0.034		
D10 (ES)	6	0.34	0.019		
D50	6	0.70	0.017		
D60	6	0.79	0.010		
D15/D85	6	0.35	0.014		
D80/D30	6	1.95	0.064		
Cc	6	1.00	0.051		
Cu	6	2.35	0.111		



Query

Query Selections
Date Created 02/21/2025
Date Range 02/14/2025 - 02/21/2025
Plant Ortona Sand Company (FDOT Pit # 05-045)
Sample Type Shipping